



130A Jericho Turnpike, Floral Park, New York 11001  
T 516 358 2955 F 516 358 1780 www.taylorenvironmental.com

May 2, 2014

Ms. Erin Brower  
New York City School Construction Authority  
Industrial and Environmental Hygiene  
30-30 Thomson Avenue  
Long Island City, NY 11101

**RE: Public School 63M**  
**121 East 3<sup>rd</sup> Street, New York, New York**  
**Project #: M063-46481 LLW#: 078063**

Dear Ms. Brower,

Asbestos abatement work was performed at the above referenced school on May 1, 2014. Abtron Associates Inc. was the abatement contractor and Taylor Environmental Group, Inc. performed the air monitoring and project monitoring during the abatement work. The following chart indicates work area location, amount and type of ACM and method of abatement.

| Work Area   | Type of ACM         | Amount of ACM    | Abatement Method   |
|---|---------------------|------------------|--|
| Exterior Façade –North<br>Elevation<br>Sections 2/3/4 | Red Paint On Façade | 1428 Square Feet | Exterior Vertical Surface<br>(1 <sup>st</sup> Application Removal) |
| Exterior Façade –North<br>Elevation<br>Sections 5 /6  | Red Paint On Façade | 824 Square Feet  | Exterior Vertical Surface<br>(1 <sup>st</sup> Application)         |

In addition, a visual inspection of the above referenced locations was conducted by a Taylor Environmental Group, Inc. Project Monitor in accordance with New York City Title 15, New York State Industrial Code Rule #56, AHERA and all other applicable federal, state and local regulations. Air clearance for reoccupancy was achieved in the above referenced locations on May 1, 2014. Based upon the final visual inspection and the sample results, the above referenced locations have met re-occupancy criteria as defined in all applicable federal, state and local regulations.

If you have any questions, or require further information, please contact me at our Floral Park office.

Sincerely,

Chris McElgun  
Project Manager

Cc: W. Hernandez – C/Engineer  
D. Cameron – Principal (PS 63M)  
D. Speilberg – Principal (TNS)  
C. Dumitrescu – SCA PO  
M. Joseph – (TNS)